



## FIRE EXTINGUISHER MAINTENANCE

Inspect your unmanned fire extinguishers at least once a month (more often in severe environments). Fire extinguisher maintenance is important for everyone's safety.

You must ensure that:

- The extinguisher is not blocked by lighting, equipment, coats or other objects that could interfere with its operation in an emergency.
- The pressure is at the recommended level. The needle on the pressure gauge should be in the green zone - not too high and not too low.
- The nozzle or other parts are not hindered in any way.
- The glass fusible link is intact.
- There are no dents, leaks, rust, chemical deposits and/or other signs of abuse/wear.
- Wipe off any corrosive chemicals, oil, gunk etc. that may have deposited on the extinguisher.

Fire extinguishers should be pressure tested (a process called hydrostatic testing) after a number of years to ensure that the cylinder is safe to use. Consult your telephone directory for a fire extinguisher service company in your area for a qualified technician to perform this test. If the extinguisher is damaged or needs recharging, replace or service it immediately!

**IMPORTANT:** Recharge or replace all extinguishers immediately after use regardless of how much they were used.

What is the difference between a fire extinguisher inspection and fire extinguisher maintenance?

### INSPECTION

An inspection is a "quick check" to give reasonable assurance that a fire extinguisher is fully charged and operable. The value of an inspection lies in the frequency, regularity, and thoroughness with which it is conducted. The frequency will vary from weekly to monthly, based on the needs of the situation. Inspections should always be conducted when extinguishers are initially placed in service and thereafter at approximately 30-day intervals.

### MAINTENANCE

Fire extinguishers should be maintained at regular intervals (at least once a year). Maintenance is a "thorough check" of the extinguisher. It is intended to give maximum assurance that an extinguisher will operate effectively and safely. It includes a thorough examination and any necessary repair, recharging or replacement. It will normally reveal the need for hydrostatic testing of an extinguisher. Consult your telephone directory for a fire extinguisher service company in your area.